

The cost of a small membrane bioreactor

C. H. Lo, E. McAdam and S. Judd

ABSTRACT

The individual cost contributions to the mechanical components of a small membrane bioreactor (MBR) (100–2,500 m³/d flow capacity) are itemised and collated to generate overall capital and operating costs (CAPEX and OPEX) as a function of size. The outcomes are compared to those from previously published detailed cost studies provided for both very small containerised plants (<40 m³/day capacity) and larger municipal plants (2,200–19,000 m³/d). Cost curves, as a function of flow capacity, determined for OPEX, CAPEX and net present value (NPV) based on the heuristic data used indicate a logarithmic function for OPEX and a power-based one for the CAPEX. OPEX correlations were in good quantitative agreement with those reported in the literature. Disparities in the calculated CAPEX trend compared with reported data were attributed to differences in assumptions concerning cost contributions. More reasonable agreement was obtained with the reported membrane separation component CAPEX data from published studies. The heuristic approach taken appears appropriate for small-scale MBRs with minimal costs associated with installation. An overall relationship of net present value = $(a t^b)Q^{(-c \ln t + d)}$ was determined for the net present value where $a = 1.265$, $b = 0.44$, $c = 0.00385$ and $d = 0.868$ according to the dataset employed for the analysis.

Key words | CAPEX, costs, membrane bioreactor, NPV, OPEX

C. H. Lo
E. McAdam
S. Judd (corresponding author)
Cranfield University,
UK
E-mail: s.j.judd@cranfield.ac.uk

C. H. Lo
Ecologix Technologies,
Taiwan

S. Judd
Qatar University,
Qatar

INTRODUCTION

Immersed membrane bioreactor (iMBR) plants may either be bespoke designed or be provided as a containerised technology with only relatively minor modifications on site. All large municipal plants are designed bespoke, and the costs incurred categorised as either part of the expenditure for operation (OPEX), the cost per treated product volume, or capital (CAPEX).

There is generally little information in the peer-reviewed literature on costs, but rather more on energy demand, a key contributor to water and wastewater treatment OPEX generally and aeration energy specifically. A number of MBR energy analyses from 2010 onwards (Verrecht *et al.* 2010; Liu *et al.* 2012; Krzeminski *et al.* 2012; Itokawa *et al.* 2014; Gabarrón *et al.* 2014) have demonstrated the significance of operating at full capacity to maximise the flux and minimise the specific aeration demand (SAD_p) – the ratio of the air demanded for membrane scouring to the permeate generated. Other studies have demonstrated the benefit of operating at low solids concentrations, which reduces energy for both mixing (Fenu *et al.* 2012) and biological (or process) aeration (Schaller *et al.* 2010; Henkel *et al.* 2011; Rodríguez *et al.* 2012). Energy-based papers have tended to

illustrate the classic balance between OPEX and CAPEX (operating and capital expenditure) when considering TOTEX (total expenditure), particularly with reference to equalisation (Verrecht *et al.* 2010; Gabarrón *et al.* 2014) and waste sludge production and management (Schaller *et al.* 2010).

When considering TOTEX for the installation and operation over the entire life cycle of an installation, other factors besides energy can contribute significantly to overall cost. In such cases, it is appropriate to calculate the net present value (NPV), to account for the change in base utility and service costs, the value of the asset, and the value of money itself over the course of the plant life. The few reports in peer-reviewed literature of either TOTEX and/or NPV have tended to corroborate the importance of energy demand in determining OPEX. The energy demand appears to make up 27–34% of the total OPEX for a large (19–48 MLD, or megalitres/day, flow capacity) municipal MBR (DeCarolis *et al.* 2007; Brepols *et al.* 2010; Young *et al.* 2013, 2014). Contributions from individual OPEX items can vary significantly according to assumptions made (Figure 1) but the overall calculated 2015-corrected NPVs for the MBR




Figure 1 | Breakdown of percentage OPEX contributions, published papers.

for the analyses from these studies, based on a 19 MLD plant, are comparable at \$60–80 million.

While these heuristic studies provide representative data, they are limited to specific installations/scenarios or else are aspecific in itemisation: cost contributors are not always consistently identified, and the impact of specific items varies according to the circumstances of the site. For example, waste sludge disposal is not identified as a single cost item in the reports by some authors, yet this item contributes 21% of the OPEX at Nordkanal in Germany (Brepols *et al.* 2010); sludge management costs have been postulated as being comparable to aeration costs (Schaller *et al.* 2010). The Nordkanal analysis, conversely, excludes membrane replacement – which makes up 28% of the OPEX in the DeCarolis *et al.* (2007) study (Figure 1). Moreover, these costs are all based on relatively large flows (19,000–48,000 m³/d). There have been few full cost studies based on small-scale MBR systems, and those that have appeared have either been largely limited to OPEX (Verrecht *et al.* 2012) or have been based on small containerised systems (Fletcher *et al.* 2007). For small-scale MBRs, including containerised plants, the onus is on design simplicity and minimal manual intervention since the associated labour costs significantly add to TOTEX (Verrecht *et al.* 2012). Optimisation based on energy demand, as applied to large-scale systems, is less appropriate than system robustness in such cases.

It is of interest to assess the costs associated with the construction, installation and operation of a small to medium-sized bespoke flat sheet (FS) MBR typically applied

to small municipal wastewater flows, since these make up the vast majority of MBR installations globally. This paper aims to provide a detailed and consistent cost analysis for such MBR installations focusing on the CAPEX of individually itemised components and OPEX determined on a consistent basis. Three different flow capacities provide CAPEX and OPEX cost curves.

METHODOLOGY

The cost analysis proceeded by itemising each individual component (Table 1) of a standard treatment scheme (Figure 2) for an MLE (modified Ludzack-Ettinger) process. All components were individually specified, ostensibly in terms of size, flow capacity and power rating, and priced from supplier information or based on proprietary data with reference to the geographical area of Southern China.

The basis of the design is included in the Table 1 footnotes, with other key cost assumptions provided in Table 2. A design value of 26 Nm³ air per m³ permeate for membrane air scouring (SAD_p) was used, a significantly higher value than those normally associated with large-scale wastewater treatment ($SAD_p \sim 10$ Nm³/m³, Judd (2014)). The high SAD_p required for the smaller plants considered in the current analysis reflects a more conservative design required to minimise the risk of process upset and unscheduled manual intervention. The selected design process aeration rate (for sustaining biological treatment) of

Table 1 | MBR plant components and design basis

Category	Component(s)	ID	Description/purpose	Note
Tanks	Raw water	T1	Storage tank for inlet wastewater	
	Primary sedimentation	T2	Removal of gross, settleable solids	1
	Equalisation (EQ)	T3	Equalisation of flow	2
	Anoxic (Ax)	T4	Denitrification	3
	Aeration (Ae)	T5	Nitrification and biological oxidation	3
	Membrane	T6	Membrane separation	3
	Treated water	T7	Storage of permeate water	
	Sludge	T8	Storage of wasted sludge	
	Chemicals storage	T9,10		
Pumps	Settled sludge transfer	P1	Submerged, settled sludge to sludge storage tank	4
	Feed	P2	EQ tank through rotary screen	4
	Permeate	P3	Self-priming, membrane suction filtration	4
	Sludge return/discharge	P4	Submerged, sludge recirculation and excess	5
	Sludge transfer	P5	WAS to dewatering	6
	Chemicals	P6,7	Cleaning chemicals transfer to membrane, x2	7
	Blower	Process	B1	Biological process aeration
Membrane		B2	Membrane scouring	9
Mixer	EQ tank mixer	X1	High speed, equalisation tank	
	Ax tank mixer	X2	Low speed, anoxic tank	
Screen	Rotary screen	S1	Fine screening of feed	
Membrane	Membrane module	M1	FS membrane plus frame with built-in aerator	10
Diffusers	Fine bubble diffuser	D1	Process aeration	
	Coarse bubble diffuser	D2	Membrane aeration	

1 0.48–0.58 hours hydraulic residence time (HRT).

2 6.4–6.5 hours HRT.

3 8.1–8.2 hours HRT total.

4 Flow capacity of 125% of feed flow.

5 Flow capacity of 250% of feed flow (Recycle ratio = 2.5Q).


6 Flow capacity of 10–12% of feed flow.

7 10 L/min, applied weekly for 120 minutes total.

8 Process aeration rate $SAD_{p,bio} = 11.5 \text{ Nm}^3/\text{m}^3$; aeration energy = 0.017–0.024 kWh/Nm³.

9 Membrane air scour rate $SAD_p = 26 \text{ Nm}^3/\text{m}^3$; aeration energy = 0.015–0.022 kWh/Nm³.

10 Flux of 0.5 m/d.

**Figure 2** | Plant schematic; see Table 1 for codes.

11.5 Nm³/m³ assumes intermittent operation of the process blower for moderate strength municipal wastewaters, based on a dissolved oxygen concentration set-point concentration of 1–2 mg/L.

Three different plant capacities were considered: 100, 500 and 2,500 m³/d. Specifications for the categorised components listed in Table 1 (tanks T1–T8, pumps P1–P7, blowers B1 and B2, mixers X1 and X2, screen S1, membrane M1, and diffuser D1) were used to obtain itemised costs provided by regional suppliers in Taiwan and Southern China. Costs within each category were then summed for further analysis of CAPEX trends. The OPEX in \$ per m³ permeate was determined according to the combined cost of energy demand, critical component replacement, chemical consumption, waste management/disposal and labour (Judd 2014):

$$\text{OPEX} = L_E E_{tot} + 365 L_M / (J t_{mem}) + L_C + L_W + L_L \quad (1)$$

where L_E is the cost of electrical energy in \$/kWh, L_M the membrane cost per m² membrane area, J the flux in m/d and t_{mem} the membrane life in years. L_C , L_W and L_L represent the

Table 2 | Key cost components

Cost component			Value (range)
Electrical energy cost	L_E	\$/kWh	0.1
Membrane cost	L_M	\$/m ²	79.16
Chemicals cost	L_C	\$/m ³	0.0091
Membrane life	t_{mem}	y	5
Plant life	t	y	5–20
Margin, proportion of equipment purchase costs			15%
Assembly, proportion of CAPEX			20%
Discount rate			5%
Labour			
Annual salary of operator/maintenance engineer		\$/y	15,167
O/h on salary (incl. employer tax & pension contrib.)			30%
No. working hours per year		hrs/y	2,700
Proportion of working day spent maintaining MBR			15%
Flow, Q		m ³ /d	100 500 2,500
Number of staff			1 2 5
Labour cost	L_L	\$/m ³	0.061 0.024 0.012
Contribution of labour costs to total			14.0% 5.6% 2.8%

specific costs per m³ treated water for chemicals consumption, waste disposal and labour, with all these other than waste disposal included in the current analysis. The total specific energy demand E_{tot} in kWh/m³ is provided by the sum of the power consumption rating W in kW of the individual component, the (estimated) fractional operational period τ (hours per day of operation divided by 24) and the permeate flow Q_p in m³/d:

$$E_{tot} = \sum \frac{24W\tau}{Q_p} \quad (2)$$

CAPEX and OPEX can be combined to estimate the averaged NPV according to the simplified relationship (Verrecht et al. 2010):


$$NPV = -OPEX \frac{1 - (1+i)^{-t}}{i} - CAPEX \quad (3)$$

where i the annual discount rate and t the amortisation period (or plant life) in years. The above equation allows for inflation and assumes zero residual value of the plant at the end of its life.

All costs for the literature data were converted to US\$ based on annual retail price index data.

RESULTS AND DISCUSSION

The outcomes of the CAPEX analysis reveal that 70–94% of the capital equipment cost is taken up by the membranes and diffusers, the proportion increasing with plant size (Figure 3(a)). A consideration of energy demand reveals

**Figure 3** | (a) Capital cost and (b) energy demand contributions at the three different flow capacities.

the proportional energy contribution of screening and stirring to decrease with size (Figure 3(b)). This arises from the practical limitation of sizing these items for the smallest installation: the same mixer and screen were fitted for both the 100 and 500 m³/d plants, such that the equipment for the smallest plant is oversized.

Correlations for absolute costs (Figure 4) reveal the expected decrease in specific cost (cost per unit product water) with plant capacity. According to these data, based on the available cost data and conditions outlined in Tables 1 and 2, cost trends follow the relationships with flow capacity Q :

$$\text{CAPEX} = 1060 Q^{0.872} \quad (4)$$

$$\text{OPEX} = -0.0509 \ln Q + 0.664 \quad (5)$$

The exponent value for the CAPEX equation (Equation (4)) approaches unity, reflecting the expected low economy of scale associated with a modular treatment process and the dominant contribution of the membrane assembly to the overall equipment costs. The decrease in OPEX with capacity arises primarily from the oversizing of components at the smallest scales.

Extrapolating these trends to the higher flows on which analyses conducted by previous authors were based permits comparison with the mean reported published data (Figure 5). Data from such studies relate to the membrane and ancillary capital equipment component specifically, this being considered most pertinent to the current study. Results show the OPEX trend to be in good agreement with the mean data

from the identified studies. The sharp increase in OPEX at low flows reflects trends reported by other authors (Fletcher et al. 2007; Brepols et al. 2010; Verrecht et al. 2012). The extent of this increase is highly dependent on values assigned to key contributors such as peak loading factor, electrical and labour costs, and the degree of manual intervention.

Cost estimates at low flows are challenged by variations in the degree of contingency assumed. The peak loading factors and the associated oversizing demanded at low flows have led to recorded mean specific energy demand values of between 1.8 kWh/m³ (Brepols et al. 2010) to as high as 10 kWh/m³ (Verrecht et al. 2012; Itokawa et al. 2014). For the Verrecht et al. study, labour costs were calculated to contribute more than half the operating cost. Moreover, a study of 84 municipal MBR installations between 2,000 and 22,000 m³/d capacity revealed the number of FTE (full time equivalent) operators per 1,000 m³/d of treated wastewater to vary between 0.3 and 2.5 (Mathis 2011), the ratio increasing with decreasing flow capacity. The corresponding range of values adopted for the current study is 0.3 FTE per 1,000 m³/d at the highest flow considered to 1.5 FTE at the lowest.

OPEX estimates are subject to increased imprecision at low flows (<500 m³/d). However, given a consistent set of assumed values for the key OPEX components in Equation (1), the trend above 500 m³/d flow capacity appears to be reasonably representative. Trends in CAPEX, conversely, are more vagarious – primarily due to the different scope and itemisation of costs in published studies combined with errors introduced by overly simplistic normalisation (Newnan et al. 2013). The projected CAPEX of a 19,000 m³/d plant is




Figure 4 | Cost and energy data at the three different flow capacities.




Figure 5 | Cost trends (Equations (3) and (4)) against reported data for MBR OPEX and membrane component CAPEX.

around \$6 million according to the current study. This figure is 86% of the mean membrane equipment cost determined by DeCarolis *et al.* (2007), and around half that of the corresponding cost calculated by Young *et al.* (2013). The only other cost study detailing individual components and based on low flows, in this case employing containerised MBR systems, reported equivalent CAPEX figures (in 2015 \$) of around 49–62k USD equipment costs at the maximum flow of 40 m^3/d considered in their study (Fletcher *et al.* 2007). This is comparable to the CAPEX of \$59k determined for the smallest plant of 100 m^3/d considered in the current study. Moreover, the CAPEX figure for the membrane component

of the cost quoted by Brepols *et al.* (2010) for a 10,000 population equivalent plant (assumed to equate to a flow of 2,500 m^3/d) was slightly lower than the projected value based on Equation (3) (Figure 5).

The mean NPV (Figure 6(a)) determined at each flow capacity follows the general trend with plant life t (with an R^2 value of > 0.985 in all cases):

$$NPV = at^b \tag{6}$$

where a and b are empirical constants and the exponent b varies between 0.419, for the largest plant, and 0.406 for




Figure 6 | NPV vs. (a) plant life at the three different flow capacities and (b) flow capacity at five different plant life values.

the smallest. Plotting NPV vs. Q (in m^3/d) at plant life values between 1 and 20 years generates a series of cost curves (Figure 6(b)) following the same exponential form as above (i.e. $\text{NPV} = mQ^n$). Simple curve fitting of the coefficient and exponent values for these cost curves provides the following overall relationship for NPV as a function of flow capacity Q and plant life t in years:

$$\text{NPV, \$} = (1265t^{0.44})Q^{(-0.00385\ln t + 0.868)} \quad (7)$$

Thus, according to the cost data in Table 2 and based on the generalised OPEX equation (Equation (1)):

- the plant NPV follows a power law relationship with both flow and plant life;
- the coefficient of the power law relationship between NPV and flow Q follows an approximate square root relationship with plant life t ; and
- the exponent value for the above NPV vs. Q equation decays logarithmically with plant life.

There appear to have been no cost functions previously published for MBR installations. However, Equation (7) is consistent with the general expectation of decreased specific costs (cost per unit volume water treated) with both flow capacity and plant life. The quantitative NPV of \$22 million USD determined at $Q = 19,000 \text{ m}^3/\text{d}$ and a 20y plant life is considerably lower than the \$55–80 million range calculated by previous authors for the same conditions since it is ostensibly limited to the membrane and equipment component alone. Installation and other site-specific costs outside of those directly relating to capital equipment (e.g. civil, mechanical and electrical) make up a more significant proportion of the costs for large-scale municipal installations.

CONCLUSIONS

An analysis of the cost of a small membrane bioreactor, 500–2,500 m^3/h capacity and based on flat sheet membrane technology, has been conducted based on individual itemisation encompassing both purchase cost and energy demand. The analysis provides a cost curve, the cost as a function of flow and plant life, and reveals:

- CAPEX to increase with flow Q according to a power law relationship with an exponent value of 0.87;
- OPEX (per m^3 treated water) to decrease logarithmically with flow, with an intercept of ~ 0.45 ;

- NPV (net present value in \$) to increase with flow Q in m^3/d and plant life t in years according to the equation:

$$\text{NPV} = at^b Q^{(-c\ln t + d)}$$

where, according to the dataset employed, $a = 1.265$, $b = 0.44$, $c = 0.0039$ and $d = 0.87$.

The trend determined for OPEX was in good agreement with that reported from three other studies of larger-scale plants. CAPEX and NPV were both significantly lower, however, since these parameters are largely associated with the MBR technology *per se* rather than ancillary installation costs (such as civil, mechanical and electrical, and miscellaneous site work). It is concluded that this heuristic approach is appropriate to small-scale installations ($\leq 5,000 \text{ m}^3/\text{d}$) and/or the equipment component of larger MBRs, but requires modification for larger-scale installations.

ACKNOWLEDGEMENT

The authors are grateful to Ecologix Technologies Asia Pacific, Inc., Taiwan, for providing technical and cost data for this article.

REFERENCES

- Brepols, B., Schäfer, H. & Engelhardt, N. 2010 Considerations on the design and financial feasibility of full-scale membrane bioreactors for municipal applications. *Water Sci. Technol.* **61** (10), 2461–2468.
- DeCarolis, J., Adham, S., Pearce, W. R., Hirani, Z., Lacy, S. & Stephenson, R. 2007 Cost trends of MBR systems for municipal wastewater treatment. In: *Proceedings of the Water Environment Federation, 13–17 October, San Diego*, pp. 3407–3418.
- Fenu, A., De Wilde, W., Gaertner, M., Weemaes, M., de, Gueldre, G. & Van De Steene, B. 2012 Elaborating the membrane life concept in a full scale hollow-fibers MBR. *J. Membrane Sci.* **421–422**, 349–354.
- Fletcher, H., Mackley, T. & Judd, S. 2007 The cost of a package plant membrane bioreactor. *Water Res.* **41**, 2627–2635.
- Gabarrón, S., Ferrero, G., Dalmau, M., Comas, J. & Rodríguez-Roda, I. 2014 Assessment of energy-saving strategies and operational costs in full-scale membrane bioreactors. *J. Environ. Management* **134**, 8–14.
- Henkel, J., Cornel, P. & Wagner, M. 2011 Oxygen transfer in activated sludge – new insights and potentials for cost saving. *Water Sci. Technol.* **63** (2), 3034–3038.
- Itokawa, H., Tsuji, K., Yamashita, K. & Hashimoto, T. 2014 Design and operating experiences of full-scale municipal membrane bioreactors in Japan. *Water Sci. Technol.* **69** (5), 1088–1093.

- Judd, S. 2014 *Industrial MBRs*, Judd and Judd Ltd, Cranfield, UK.
- Krzeminski, P., van der Graaf, J. H. J. M. & van Lier, J. B. 2012 Specific energy consumption of membrane bioreactor (MBR) for sewage treatment. *Water Sci. Technol.* **65**, 380–392.
- Liu, H. Y., Freeman, B., Sunano, S., Munehiro, N., Bartels, C. & Oda, Y. 2012 Stable operation of MBR under high permeate flux. *Water Practice Technol.* **7** (4), 1–7.
- Mathis, K. 2011 MBRs for cost-effective wastewater treatment. *Water and Wastes Digest*, 14 October 2011.
- Newnan, D. G., Lavelle, J. P. & Eschenbach, T. G. 2013 *Engineering Economic Analysis*, 12th edn. Oxford University Press, USA.
- Rodríguez, F. A., Reboleiro-Rivas, P., Osorio, F., Martínez-Toledo, M. V., Hontoria, E. & Poyatos, J. M. 2012 Influence of mixed liquid suspended solids and hydraulic retention time on oxygen transfer efficiency and viscosity in a submerged membrane bioreactor using pure oxygen to supply aerobic conditions. *Biochem. Eng. J.* **60**, 135–141.
- Schaller, J., Drews, A. & Kraume, M. 2010 Development of a cost model for membrane bioreactors including sludge handling costs. *Desalination and Water Treatment* **18**, 315–320.
- Verrecht, B., Nopens, I., Maere, T., Brepols, C. & Judd, S. 2010 The cost of a large-scale hollow fibre MBR. *Water Res.* **44**, 5274–5283.
- Verrecht, B., James, C., Germain, E., Birks, R., Barugh, A., Pearce, P. & Judd, S. 2012 Economical evaluation and operating experiences of a small scale MBR for non-potable reuse. *J. Environ. Eng.* **138**, 594.
- Young, T., Smoot, S., Peeters, J. & Côté, P. 2013 When does building an MBR make sense? How variations of local construction and operating cost parameters impact overall project economics. *Proc. Water Environment Federation.* **8**, 6354–6365.
- Young, T., Smoot, S., Peeters, J. J. & Côté, P. 2014 Cost-effectiveness of membrane bioreactors treatment system for low-level phosphorus reduction from municipal wastewater. *Water Practice Technol.* **9** (3), 316–323.

First received 21 May 2015; accepted in revised form 10 July 2015. Available online 23 July 2015